Dolores Carpinelli <dcarpinelli@veronanj.org>

DUE 10-30-26- DEPT REVIEW- 12 Pompton Avenue

Len Mendola <lmendola@veronanj.org> Wed, Oct 28, 2026 at 12:35 PM
To: Dolores Carpinelli <dcarpinelli@veronanj.org>

Good morning, 12 Pompton Ave
NJ LIcensed Architectural plans will be required.
The building department's concerns shall include:
Is this building fully suppressed? An egress plan shall be required.
Since this is a mixed use building, plans must show the most restrictive and ratings must be designed according to most restrictive.
Also, building type shall be listed and all other required plans per NJ IBC 2024 and NJ UCC 5:23 rehab code.
Thank you

On Wed, Oct 28, 2026 at 9:30 AM Dolores Carpinelli <dcarpinelli@veronanj.org> wrote:
[Quoted text hidden]

--
Len Mendola
Construction Official/Building Sub Code
Township of Verona
Office 973-857-4836
Email: lmendola@veronanj.org