



Dolores Carpinelli <dcarpinelli@veronanj.org>

DUE 7-24; Department Review- 3 Claridge Road, Flor Da Vida

Len Mendola <lmendola@veronanj.org>

Mon, Jul 20, 2026 at 1:48 PM

To: Dolores Carpinelli <dcarpinelli@veronanj.org>

Preliminary review: Please make sure all fire ratings per NJ IBC 2021 are met and egress plans shall be included in submitted NJ Licensed Architect drawings.

Furthermore, please include the Use, Construction Type and Occupancy load of tenant fit out/building.

Thank you

[Quoted text hidden]

--

Len Mendola

Construction Official/Building Sub Code

Township of Verona

Office 973-857-4836

Email: lmendola@veronanj.org