



Dolores Carpinelli <dcarpinelli@veronanj.org>

DUE 7-24 : Department Review -39 Otsego Road

Sarfeen Tanweer <stanweer@boswellengineering.com>

Wed, Jul 8, 2026 at 9:28 AM

To: Dolores Carpinelli <dcarpinelli@veronanj.org>

Cc: Kathleen Miesch <kmiesch@veronanj.org>, Michael Caggiano <mcaggiano@boswellengineering.com>

Hi Dee Dee,

I have reviewed the application documents for 39 Otsego Road. The project does not qualify as a minor development so an engineering review is not required. Therefore, we have not prepared an official review letter. Please see below for our minor comments that the Applicant shall address:

1. The Applicant shall confirm in testimony that no regrading is proposed in the rear yard of the property.
2. The Applicant shall provide testimony regarding the existing site drainage patterns and if the dwelling currently experiences any flooding issues.
3. All roof leaders and footing drains shall be directed onto an absorbent surface as grass, mulch, rock or soil so the discharge will be dissipated and not immediately drained to the Township Right-of-Way or adjacent properties.

If you have any questions, please let me know.

Thank you

Sarfeen Tanweer, P.E.

SENIOR DESIGN ENGINEER

WATER SERVICES

BOSWELL

☎ 201 641 0770

330 Phillips Avenue

South Hackensack, NJ 07606

boswellengineering.com



From: Dolores Carpinelli <dcarpinelli@veronanj.org>

Sent: Tuesday, July 7, 2026 10:43 AM

To: Christopher Kiernan <christopher.kiernan@veronapolice.org>; Matt Gifford <mgifford@veronanj.org>; Nick Polisenio <firechief@veronanj.org>; Connor McCann <cmccann@veronanj.org>; Sagar Patel <spatel@bloomfieldtwpnj.com>; Carol Thomas <cthomas@veronanj.org>; Jessica Pearson <jpearson@veronanj.org>; Len Mendola <lmendola@veronanj.org>; Michael Caggiano <mcaggiano@boswellengineering.com>; Sarfeen Tanweer <stanweer@boswellengineering.com>; chief@veronars.org; president@veronars.org

Cc: Kevin O'Sullivan <kosullivan@veronanj.org>; Michael Kraus <mkraus@veronanj.org>; Kathleen Miesch <kmiesch@veronanj.org>

Subject: DUE 7-24 : Department Review -39 Otsego Road

Kevin O'Sullivan, Township Manager **OPTIONAL

[Quoted text hidden]

Visit us on the web at www.VeronaNJ.org

[Quoted text hidden]