



Dolores Carpinelli <dcarpinelli@veronanj.org>

DUE 7-24 - Department Review for 96 Pompton Avenue, Block 807, Lot 13

Len Mendola <lmendola@veronanj.org>

Mon, Jul 20, 2026 at 1:57 PM

To: Dolores Carpinelli <dcarpinelli@veronanj.org>

Good afternoon, 96 Pompton Ave

Please make sure an egress plan is submitted with NJ Licensed Architect drawings and please specify the use, construction type and occupancy load. Finally, please make sure, if required, all spas are protected with a safety cover.
Thank you

On Mon, Jul 20, 2026 at 10:41 AM Dolores Carpinelli <dcarpinelli@veronanj.org> wrote:

[Quoted text hidden]

--

Len Mendola
Construction Official/Building Sub Code
Township of Verona
Office 973-857-4836
Email: lmendola@veronanj.org