Hello,

I don't see the fire department connection locations.

Can you please provide.

Nick Poliseno
Chief
Verona Fire Department
880 Bloomfield Ave
Verona NJ 07044

On Thu, Nov 5, 2026 at 1:09 PM Dolores Carpinelli <dcarpinelli@veronanj.org> wrote:
[Quoted text hidden]

Dolores Carpinelli <dcarpinelli@veronanj.org> Mon, Nov 23, 2026 at 11:06 AM
To: Nick Poliseno <npoliseno@veronanj.org>
Bcc: Dolores Carpinelli <dcarpinelli@veronanj.org>

Good Morning Mr. Poliseno,

The following is a response from the Applicant's engineer regarding your question about fire connection locations.

Per our civil engineer, the fire department connections will be shown on the MEP drawings included in the Building Department permit set, which has not yet been completed.

The water lines are shown on the lower-level grading and utility plan in the civil set, Sheet C-400. The water lines connect to the plumbing room located on Claremont Avenue. They connect to Bloomfield Avenue because it has the larger water line (10 inches). My understanding is that the fire department connection will be located at the plumbing room on Claremont Avenue.

The Applicant is aware that Fire Department approval will be required, and we would request that this be included as a condition of approval.

Kind Regards,
Dee Dee Carpinelli
Secretary, Planning Board and Board of Adjustment
Township of Verona
880 Bloomfield Avenue
Verona, NJ 07044
973-857-4773
dcarpinelli@veronanj.org

[Quoted text hidden]

Nick Poliseno <npoliseno@veronanj.org> Mon, Nov 23, 2026 at 11:17 AM
To: Dolores Carpinelli <dcarpinelli@veronanj.org>

Thank you

The primary hydrant for 420 Bloomfield is on the southside of Bloomfield ave, requiring all 4 lanes of traffic to be closed for use. The Fire Dept is requesting the developer add a new hydrant on the north side of Bloomfield ave, as well as adding a second fire dept connection on the Claremont ave side.

Nick Poliseno
Chief
Verona Fire Department

880 Bloomfield Ave
Verona NJ 07044

[Quoted text hidden]