



DUE 9-15-26 - Dept Review- REVISED Plans Our Lady of the Lake

Matt Gifford <mgifford@veronanj.org> Wed, Sep 2, 2026 at 12:55 PM
To: Dolores Carpinelli <dcarpinelli@veronanj.org>
Cc: Nick Poliseno <firechief@veronanj.org>, Christopher Kiernan <christopher.kiernan@veronapolice.org>

Hi Dee Dee,

My primary concern at this time is the area of the parking lot nearest the buildings where the parking stalls off the "by-pass lane" are labeled "drop off". That area should be posted as a fire lane with no stopping or standing allowed.

Additionally, is the width of that by-pass lane sufficient for the ladder truck outriggers to deploy if vehicles are parked on either side? I believe we would need a minimum width of 16 feet.

[Quoted text hidden]

--
Thank You,
Matthew Gifford
Fire Official
Bureau of Fire Prevention
Township of Verona
880 Bloomfield Avenue
Verona, NJ 07044
Office - (973) 857- 4761
<https://www.veronanj.org/fireprevention>

The information contained in this e-mail is intended only for the use of the above named individual or entity. If you are not the intended recipient, you are hereby notified that pursuant to the Federal Communications Act of 1934, you are prohibited from making any disclosure, copy and/or distribution hereof as well as taking any action in reliance on the contents thereof. If you have received this email in error, please notify us immediately.